

Evidence of Performance

Air permeability, Watertightness, Resistance to wind load



Test Report

No. 15-001426-PR02

(PB-A01-02-en-01)

Client New Home for World
Projects LLC
PO Box 594 | PC 320
Sultanate of Oman
Barka
Oman

Product Tilt and turn window

Designation System designation: New Home 60 Class A

Performance-relevant product details Material: PVC-U/white

Overall dimensions (W x H) 920 mm x 1,320 mm

Special features

Basis

EN 14351-1:2006+A1:2010

Test standard/s:

EN 1026:2000-06

EN 1027:2000-06

EN 12211:2000-06

Correspond/s to the national standard/s (e.g. DIN EN)

Representation



Results

Air permeability according to EN 12207:1999-11



Class 4

Watertightness according to EN 12208:1999-11



Class 4A

Resistance to wind load
according to EN 12210:1999-11/AC:2002-08



Class C4 / B4

Instructions for use

The results obtained can be used by the manufacturer for preparing the Declaration of Performance in accordance with the Construction Products Regulation 305/2011/EU. The provisions of the applicable product standard have to be observed.

Validity

The data and results refer solely to the tested and described specimen. Classification remains valid as long as the product and the above basis remain unchanged. The results can be extrapolated under the manufacturer's own liability subject to observance of the relevant specifications set out by the applicable product standard. This test/evaluation does not allow any statement to be made on any further characteristics regarding performance and quality of the construction presented; in particular the effects of weathering and ageing were not taken into account.

Notes on publication

The ift-Guidance Sheet "Advertising with ift test documents" applies. The cover sheet can be used as an abstract.

The report contains a total of 20 pages.

ift Rosenheim

17.09.2015

Andreas Graf
Deputy Head of Testing Department
Construction Product Testing

Peter Marquardt, Dipl.-Ing. (FH)
Operating Testing Officer
Construction Product Testing